



Unit No.	1			Open Voltage	51.7			Load Voltage	46.2 @ 162A			Chg Voltage	60.1 @ 25A			15-Oct-08		
	DEKA s/n: 3568JO																	
Cell No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	
Specific Gravity	1.250	1.255	1.250	1.255	1.200	1.205	1.250	1.250	1.260	1.245	1.250	1.250	1.250	1.210	1.250	1.250	1.245	
No Load Voltage	2.152	2.162	2.170	2.195	2.141	2.116	2.158	2.158	2.194	2.179	2.184	2.179	2.172	2.161	2.173	2.185	2.146	
Load Voltage	1.939	1.930	1.936	1.936	1.903	1.910	1.934	1.939	1.953	1.942	1.944	1.916	1.933	1.905	1.946	1.950	1.942	
Chg Voltage	2.512	2.548	2.576	2.584	2.406	2.313	2.557	2.554	2.587	2.573	2.566	2.566	2.577	2.505	2.560	2.584	2.529	
NL to LD Diff.	0.213	0.232	0.234	0.259	0.238	0.206	0.224	0.219	0.241	0.237	0.240	0.263	0.239	0.256	0.227	0.235	0.204	
SG to NL voltage	0.902	0.907	0.92	0.94	0.941	0.911	0.908	0.908	0.934	0.934	0.934	0.929	0.922	0.951	0.923	0.935	0.901	
Cell No.	18	19	20	21	22	23	24											
Specific Gravity	1.245	1.200	1.235	1.240	1.250	1.130	1.240											
No Load Voltage	2.171	2.122	2.136	2.138	2.142	2.050	2.162											
Load Voltage	1.944	1.918	1.938	1.932	1.942	1.847	1.921											
Chg Voltage	2.576	2.376	2.402	2.500	2.533	2.229	2.540											
NL to LD Diff.	0.227	0.204	0.198	0.206	0.2	0.203	0.241											
SG to NL voltage	0.926	0.922	0.901	0.898	0.892	0.92	0.922											




Cells are weak due to sulphation but would also need acid balancing. Not sure if cell #23 will recover.

Unit No.	2		Open Voltage	50.5				Load Voltage	46.8 @ 167A				Chg Voltage	59.8 @ 30A				16-Oct-08
	DEKA s/n: 3572JO																	
Cell No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	
Specific Gravity	1.245	1.250	1.250	1.250	1.250	1.250	1.240	1.250	1.245	1.245	1.245	1.240	1.235	1.245	1.250	1.245	1.250	
No Load Voltage	2.105	2.113	2.117	2.109	2.110	2.108	2.102	2.114	2.108	2.109	2.108	2.110	2.103	2.110	2.114	2.108	2.111	
Load Voltage	1.961	1.964	1.971	1.967	1.965	1.950	1.946	1.971	1.964	1.969	1.967	1.934	1.960	1.967	1.968	1.965	1.967	
Chg Voltage	2.429	2.528	2.523	2.524	2.458	2.526	2.510	2.503	2.510	2.480	2.477	2.520	2.500	2.448	2.449	2.494	2.494	
NL to LD Diff.	0.144	0.149	0.146	0.142	0.145	0.158	0.156	0.143	0.144	0.140	0.141	0.176	0.143	0.143	0.146	0.143	0.144	
SG to NL voltage	0.860	0.863	0.867	0.859	0.86	0.858	0.862	0.864	0.863	0.864	0.863	0.87	0.868	0.865	0.864	0.863	0.861	
Cell No.	18	19	20	21	22	23	24											
Specific Gravity	1.245	1.240	1.245	1.245	1.245	1.240	1.235											
No Load Voltage	2.103	2.107	2.107	2.110	2.108	2.101	2.110											
Load Voltage	1.952	1.946	1.960	1.965	1.964	1.948	1.944											
Chg Voltage	2.444	2.547	2.549	2.521	2.487	2.492	2.504											
NL to LD Diff.	0.151	0.161	0.147	0.145	0.144	0.153	0.166											
SG to NL voltage	0.858	0.867	0.862	0.865	0.863	0.861	0.875											



Cells are good and even but would need to have the acid raised to at least 1.270

Unit No.	3			Open Voltage	52.8			Load Voltage	46.7 @ 163A			Chg Voltage	60.9 @ 22A			15-Oct-08		
	DEKA s/n: 5729EP																	
Cell No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	
Specific Gravity	1.260	1.270	1.255	1.255	1.260	1.260	1.260	1.255	1.260	1.250	1.255	1.255	1.250	1.255	1.250	1.255	1.260	
No Load Voltage	2.209	2.212	2.207	2.203	2.199	2.208	2.210	2.201	2.200	2.199	2.201	2.199	2.194	2.197	2.191	2.199	2.203	
Load Voltage	1.964	1.958	1.964	1.949	1.963	1.957	1.938	1.960	1.964	1.944	1.959	1.950	1.956	1.964	1.955	1.950	1.960	
Chg Voltage	2.575	2.556	2.588	2.545	2.554	2.567	2.563	2.512	2.545	2.496	2.507	2.547	2.533	2.549	2.524	2.513	2.516	
NL to LD Diff.	0.245	0.254	0.243	0.254	0.236	0.251	0.272	0.241	0.236	0.255	0.242	0.249	0.238	0.233	0.236	0.249	0.243	
SG to NL voltage	0.949	0.942	0.952	0.948	0.939	0.948	0.95	0.946	0.94	0.949	0.946	0.944	0.944	0.942	0.941	0.944	0.943	
Cell No.	18	19	20	21	22	23	24											
Specific Gravity	1.260	1.255	1.250	1.255	1.250	1.250	1.250											
No Load Voltage	2.207	2.196	2.196	2.196	2.193	2.192	2.195											
Load Voltage	1.955	1.928	1.957	1.963	1.955	1.953	1.945											
Chg Voltage	2.560	2.535	2.532	2.561	2.538	2.538	2.536											
NL to LD Diff.	0.252	0.268	0.239	0.233	0.238	0.239	0.25											
SG to NL voltage	0.947	0.941	0.946	0.941	0.943	0.942	0.945											




Cells are good and even but would need to have the acid raised to at least 1.270

Unit No. 4 **Open Voltage** 51.7 **Load Voltage** 47.3 @ 163A **Chg Voltage** 59.5 @ 32A 15-Oct-08
DEKA s/n: 5714EP


Cell No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
Specific Gravity	1.190	1.235	1.260	1.225	1.215	1.210	1.255	1.200	1.265	1.260	1.265	1.270	1.270	1.270	1.270	1.270	1.260
No Load Voltage	2.139	2.158	2.173	2.147	2.144	2.141	2.168	2.128	2.174	2.169	2.171	2.177	2.179	2.173	2.174	2.175	2.166
Load Voltage	1.974	1.989	1.997	1.984	1.972	1.967	1.994	1.974	2.001	1.998	1.998	1.993	1.973	1.999	2.000	2.005	1.997
Chg Voltage	2.333	2.463	2.590	2.366	2.313	2.366	2.613	2.313	2.572	2.572	2.544	2.572	2.558	2.536	2.563	2.561	2.568
NL to LD Diff.	0.165	0.169	0.176	0.163	0.172	0.174	0.174	0.154	0.173	0.171	0.173	0.184	0.206	0.174	0.174	0.170	0.169
SG to NL voltage	0.949	0.923	0.913	0.922	0.929	0.931	0.913	0.928	0.909	0.909	0.906	0.907	0.909	0.903	0.904	0.905	0.906

Cell No.	18	19	20	21	22	23	24
Specific Gravity	1.220	1.160	1.190	1.235	1.255	1.250	1.255
No Load Voltage	2.140	2.112	2.132	2.162	2.172	2.166	2.170
Load Voltage	1.973	1.948	1.962	1.993	1.987	1.992	1.981
Chg Voltage	2.346	2.282	2.325	2.536	2.552	2.565	2.572
NL to LD Diff.	0.167	0.164	0.17	0.169	0.185	0.174	0.189
SG to NL voltage	0.92	0.952	0.942	0.927	0.917	0.916	0.915




Battery need to be acid balanced and raised to at least 1.270

Unit No.	5		Open Voltage	50.9		Load Voltage	46.8 @ 167A		Chg Voltage	60.1 @ 28A							15-Oct-08
	DEKA s/n: 4593JO																
Cell No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
Specific Gravity	1.260	1.265	1.260	1.260	1.265	1.260	1.250	1.260	1.260	1.260	1.260	1.260	1.265	1.255	1.260	1.280	1.260
No Load Voltage	2.127	2.126	2.127	2.124	2.126	2.120	2.118	2.125	2.124	2.123	2.128	2.128	2.130	2.119	2.126	2.149	2.126
Load Voltage	1.969	1.962	1.975	1.974	1.975	1.968	1.956	1.975	1.975	1.975	1.979	1.957	1.978	1.972	1.979	1.999	1.977
Chg Voltage	2.549	2.544	2.526	2.537	2.538	2.549	2.540	2.517	2.519	2.523	2.519	2.542	2.538	2.521	2.515	2.529	2.527
NL to LD Diff.	0.158	0.164	0.152	0.150	0.151	0.152	0.162	0.150	0.149	0.148	0.149	0.171	0.152	0.147	0.147	0.150	0.149
SG to NL voltage	0.867	0.861	0.867	0.864	0.861	0.86	0.868	0.865	0.864	0.863	0.868	0.868	0.865	0.864	0.866	0.869	0.866
Cell No.	18	19	20	21	22	23	24										
Specific Gravity	1.255	1.265	1.265	1.260	1.260	1.260	1.265										
No Load Voltage	2.123	2.128	2.128	2.127	2.128	2.127	2.130										
Load Voltage	1.965	1.964	1.977	1.977	1.965	1.965	1.963										
Chg Voltage	2.549	2.547	2.527	2.525	2.529	2.536	2.548										
NL to LD Diff.	0.158	0.164	0.151	0.15	0.163	0.162	0.167										
SG to NL voltage	0.868	0.863	0.863	0.867	0.868	0.867	0.865										




Cells are in good shape but would need an acid adjustment to bring it up to 1.270 minimum.

Unit No.	6		Open Voltage	53.2		Load Voltage	47.1 @ 163A		Chg Voltage	61.3 @ 29A		16-Oct-08					
	DEKA s/n: 5712EP																
Cell No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
Specific Gravity	1.260	1.270	1.265	1.270	1.215	1.240	1.270	1.255	1.260	1.260	1.260	1.260	1.265	1.265	1.265	1.260	1.260
No Load Voltage	2.202	2.222	2.232	2.231	2.199	2.199	2.237	2.217	2.220	2.222	2.220	2.222	2.226	2.227	2.220	2.218	2.218
Load Voltage	1.977	1.985	1.989	1.987	1.954	1.967	1.986	1.969	1.979	1.983	1.968	1.950	1.983	1.985	1.985	1.981	1.979
Chg Voltage	2.566	2.595	2.574	2.610	2.467	2.523	2.570	2.533	2.555	2.558	2.570	2.596	2.603	2.591	2.562	2.558	2.549
NL to LD Diff.	0.225	0.237	0.243	0.244	0.245	0.232	0.251	0.248	0.241	0.239	0.252	0.272	0.243	0.242	0.235	0.237	0.239
SG to NL voltage	0.942	0.952	0.967	0.961	0.984	0.959	0.967	0.962	0.96	0.962	0.96	0.962	0.961	0.962	0.955	0.958	0.958
Cell No.	18	19	20	21	22	23	24										
Specific Gravity	1.260	1.250	1.220	1.260	1.250	1.260	1.250										
No Load Voltage	2.215	2.194	2.203	2.223	2.223	2.222	2.199										
Load Voltage	1.978	1.970	1.950	1.973	1.970	1.968	1.959										
Chg Voltage	2.582	2.560	2.501	2.538	2.522	2.563	2.539										
NL to LD Diff.	0.237	0.224	0.253	0.25	0.253	0.254	0.24										
SG to NL voltage	0.955	0.944	0.983	0.963	0.973	0.962	0.949										




Cells #5 and 20 need acid balancing and other cells need adjusting.

Unit No.	7			Open Voltage	50.4			Load Voltage	46.2 @ 165A			Chg Voltage	59.4 @ 34A			16-Oct-08		
	DEKA s/n: 3571JO																	
Cell No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	
Specific Gravity	1.200	1.210	1.220	1.270	1.225	1.235	1.230	1.225	1.230	1.240	1.240	1.230	1.205	1.250	1.235	1.235	1.230	
No Load Voltage	2.099	2.093	2.096	2.120	2.118	2.106	2.097	2.098	2.090	2.100	2.101	2.102	2.093	2.114	2.110	2.093	2.099	
Load Voltage	1.911	1.925	1.935	1.969	1.942	1.933	1.942	1.944	1.949	1.955	1.950	1.940	1.900	1.956	1.953	1.948	1.945	
Chg Voltage	2.365	2.436	2.470	2.622	2.433	2.486	2.440	2.511	2.603	2.596	2.519	2.460	2.351	2.512	2.530	2.599	2.498	
NL to LD Diff.	0.188	0.168	0.161	0.151	0.176	0.173	0.155	0.154	0.141	0.145	0.151	0.162	0.193	0.158	0.157	0.145	0.154	
SG to NL voltage	0.899	0.883	0.876	0.85	0.893	0.871	0.867	0.873	0.86	0.86	0.861	0.872	0.888	0.864	0.875	0.858	0.869	
Cell No.	18	19	20	21	22	23	24											
Specific Gravity	1.240	1.215	1.225	1.230	1.200	1.230	1.150											
No Load Voltage	2.092	2.111	2.115	2.097	2.092	2.111	2.050											
Load Voltage	1.953	1.928	1.947	1.941	1.931	1.942	1.868											
Chg Voltage	2.621	2.358	2.415	2.498	2.388	2.464	2.236											
NL to LD Diff.	0.139	0.183	0.168	0.156	0.161	0.169	0.182											
SG to NL voltage	0.852	0.896	0.89	0.867	0.892	0.881	0.9											



Several cells are sulphated and would need a desulphation charge. Also an acid balance would be required but unsure if cell 24 will recover.

Unit No.	8		Open Voltage	52.3		Load Voltage	46.3 @ 165A		Chg Voltage	60.8 @ 23A		16-Oct-08					
	DEKA s/n: 3569JO																
Cell No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
Specific Gravity	1.240	1.250	1.240	1.245	1.230	1.250	1.250	1.170	1.240	1.245	1.235	1.245	1.235	1.240	1.235	1.235	1.240
No Load Voltage	2.143	2.179	2.188	2.194	2.177	2.186	2.200	2.148	2.183	2.191	2.183	2.194	2.186	2.183	2.185	2.183	2.184
Load Voltage	1.943	1.945	1.943	1.948	1.941	1.954	1.956	1.896	1.947	1.946	1.940	1.946	1.911	1.941	1.930	1.943	1.946
Chg Voltage	2.525	2.528	2.558	2.540	2.515	2.564	2.577	2.355	2.557	2.546	2.534	2.555	2.565	2.548	2.543	2.533	2.544
NL to LD Diff.	0.200	0.234	0.245	0.246	0.236	0.232	0.244	0.252	0.236	0.245	0.243	0.248	0.275	0.242	0.255	0.240	0.238
SG to NL voltage	0.903	0.929	0.948	0.949	0.947	0.936	0.95	0.978	0.943	0.946	0.948	0.949	0.951	0.943	0.95	0.948	0.944
Cell No.	18	19	20	21	22	23	24										
Specific Gravity	1.245	1.255	1.240	1.240	1.240	1.235	1.235										
No Load Voltage	2.192	2.205	2.156	2.187	2.192	2.181	2.145										
Load Voltage	1.940	1.942	1.941	1.944	1.943	1.918	1.940										
Chg Voltage	2.555	2.561	2.545	2.558	2.542	2.534	2.527										
NL to LD Diff.	0.252	0.263	0.215	0.243	0.249	0.263	0.205										
SG to NL voltage	0.947	0.95	0.916	0.947	0.952	0.946	0.91										



Battery would need an acid balance with emphasis on cell #8.